

WELL CONSTRUCTOR'S REPORT

Wol-6

MAY 7 1970

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Ferrysville

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
Lot 2 Block 4 T 10N, R 6W, Sec 8

3. OWNER AT TIME OF DRILLING George Johnston

4. OWNER'S COMPLETE MAIL ADDRESS Ferrysville, Wis. 54628

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
8'	15'	15'				

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		52'		60'					

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
6	Surface	90				loose sand	Surface	60
						sandstone	60	90

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	72

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
loose sand	Surface	60

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 8 GPM

Well construction completed on 4-25-1970

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 60 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 60 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison, Wis. laboratory on: 5-4-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coyman Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT <u>1005</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-------------------------------------	---------------	---------------	-----------	---------