

SEP 17 1970.

WELL CONSTRUCTOR'S REPORT

Well-6

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Freeman

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
SE 1/4 of Sec. 8 T10N R6W R7W

3. OWNER AT TIME OF DRILLING John A. Manthey

4. OWNER'S COMPLETE MAIL ADDRESS RFD Ferrisville Wis, 54628

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
6'	C.I.	TILE	C.I.	TILE
			SEWER CONNECTED	INDEPENDENT

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C.I.	TILE	60'						

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Country Cottage

7. DRILLHOLE			10. FORMATIONS					
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	48	6	48	120	Clay	Surface	20
						soft shalestone	20	33
						hard shalestone	33	90
						hard sandstone	90	120

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	48

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	20
Cement	20	48

11. MISCELLANEOUS DATA

Yield test: 5 Hrs. at 6 GPM Well is terminated 14 inches above below final grade

Depth from surface to normal water level 80 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 80 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9-14-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Roscobol, Wis, 53805

Please do not write in space below

COLIFORM TEST RESULT <u>1006</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-------------------------------------	---------------	---------------	-----------	---------