

WELL CONSTRUCTOR'S REPORT
FORM 3-15

JUL 1 - 1974

NOTE SEP 6 1974

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Freeman Ferrisville

2. LOCATION - 1/4 Section SE Section 8 Township 10N Range 6W 3. OWNER AT TIME OF DRILLING Tom Towers
OR - Grid or street no. Street name ADDRESS

AND - If available subdivision name, lot & block no. Lot #1 POST OFFICE Ferrisville, Wis. 54628

4. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN
C.I. C.I. TILE C.I. TILE SEWER CONNECTED INDEPENDENT C.I. TILE
(Record answer in appropriate block) 8'

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
C.I. TILE Village sewer

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	65	6	65	100	Clay	Surface	6	
						Clay & loose stone	6	40	
						soft sandstone	40	45	
						hard sandstone	45	100	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 18.97	Surface	65

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
Clay	Surface	6	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
Cement	6	65	Well construction completed on <u>6-17-</u> 19 <u>74</u>		

11. MISCELLANEOUS DATA		
Yield test:	<u>4</u> Hrs. at	<u>10</u> GPM
Depth from surface to normal water level	<u>22</u> ft.	Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth to water level when pumping	<u>31</u> ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison laboratory on: 6-26- 19 74

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coyman Registered Well Driller COMPLETE MAIL ADDRESS Boocobel R3 Box 84 Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>1007</u>				