

OCT 5 1982

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Honey

2. LOCATION Section or Gov't. Lot NE Section 13 Township 9N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE David Swasko

OR - Grid or Street No. Street or Road Name ADDRESS RR2

AND - If available subdivision name, lot & block No. POST OFFICE Haysville, WI ZIP CODE 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 40' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Clearwater Sump

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	64	6	64	100	broken limestone	Surface	54
						shalestone (hard)	54	81
						hard sandstone	81	100

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	A53 18.97 ^{lb} / _{ft} + Kumington Pipe & Jube sealed hand pump	Surface	64

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	64

Well construction completed on 7-28 1982

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 8 GPM Well is terminated 18 inches above final grade below

Depth from surface to normal water level 60 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 70 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 9-27-1982

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Phil Caplan Registered Well Driller Business Name and Complete Mailing Address Kenneth Corporation & Sons, Inc
Rt. 2 Box 4 Boscobel, WI 53805