

WELL CONSTRUCTOR'S REPORT

Well-6

MAY 7 1970

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Freeman

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
Central Part of Sec. 10 T10N R6W

3. OWNER AT TIME OF DRILLING Kenneth Knutson

4. OWNER'S COMPLETE MAIL ADDRESS Ferrisville, Wis. 54628

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY TILE	SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
6'	18'		18'				

CLEAR WATER DRAIN C. I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		65'			85'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dis. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	91	6	91	120	Clay	Surface	50	
						soft sandstone	50	60	
						hard sandstone	60	120	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	91

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	50
Cement	50	91

11. MISCELLANEOUS DATA

Yield test: 6 Hrs. at 12 GPM

Well construction completed on 1-24-1970

Well is terminated 8 inches  above  below final grade

Depth from surface to normal water level 85 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 90 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison, Wis. laboratory on: 5-4-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boocobol, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT <u>1016</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-------------------------------------	---------------	---------------	-----------	---------