

WELL CONSTRUCTOR'S REPORT

Well-6

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

JUL 9 1971

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Seneca

2. LOCATION (Number and street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
SW 1/4 of Sec. 10 T 10N R 6W

3. OWNER AT TIME OF DRILLING Tom Hill

4. OWNER'S COMPLETE MAIL ADDRESS RFD Ferrysville, Wis. 54628

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.
12'	20'	20'			20'

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		75'			80'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Country home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	47	6	47	120	Clay	Surface	20
						hard shalestone	20	100
						sandstone	100	120

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	47

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	20
Cement	20	47

11. MISCELLANEOUS DATA

Yield test: 6 Hrs. at 8 GPM

Well construction completed on 6-30-1971

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 70 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 75 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 7-6-1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Denneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
1017				