

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

SEP 25 1975

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Freeman

2. LOCATION - 1/4 Section SW Section 10 Township 10 N Range 6 W

OR - Grid or street no. Street name

3. OWNER AT TIME OF DRILLING Mr. Hale Seymour  
ADDRESS RFD  
POST OFFICE Ferrisville Wis. 54628

4. Distance in feet from well to nearest:

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
<u>12'</u>	<u>22'</u>	<u>22'</u>				

(Record answer in appropriate block)

CLEAR WATER DRAIN C. I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		<u>28'</u>		<del>XXXX</del>	<u>60'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>83</u>	<u>6</u>	<u>83</u>	<u>180</u>	<u>Clay</u>	<u>Surface</u>	<u>15</u>	
						<u>soft shalestone</u>	<u>15</u>	<u>60</u>	
						<u>hard shalestone</u>	<u>60</u>	<u>130</u>	
						<u>sandstone</u>	<u>130</u>	<u>180</u>	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>83</u>

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>puddle Clay</u>	<u>Surface</u>	<u>15</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>15</u>	<u>83</u>	Well construction completed on <u>9-15</u> 19 <u>75</u>		

11. MISCELLANEOUS DATA			
Yield test:	<u>3</u> Hrs. at	<u>5</u> GPM	Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level	<u>90</u> ft.	Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	<u>98</u> ft.	Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Water sample sent to <u>Madison</u>		laboratory on: <u>9-22</u> 19 <u>75</u>	

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copron Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boesefel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT <u>1019</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
----------------------------------	---------------	---------------	-----------	---------