

1. COUNTY **CRAWFORD** CHECK (✓) ONE: Town Village City Name **HANEY**

2. LOCATION **SW** 1/4 Section or Gov't. Lot Section **1A** Township **9N** Range **4W** 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE **PHILLIP DEMMER**

OR - Grid or Street No. Street or Road Name ADDRESS **N82W 7425 PINE ST**

AND - If available subdivision name, lot & block No. POST OFFICE **CEDARBURG, WI.** ZIP CODE **53012**

4. Distance in feet from well to nearest: (Record answer in appropriate block)

San. Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank											
San.	Storm	C.I.	Other	Sewer	Sewage Sump	Clearwater Dr.	Clearwater Sump	C.I.	Other	C.I.	Other	C.I.	Other	C.I.	Other	Seepage Pit	Seepage Bed	Seepage Trench	

5. Well is intended to supply water for: **COUNTRY HOME**

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	0 Surface	250			
6"	250	380			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	NEW BLACK STEEL PLAIN END	0 Surface	250
	18.97 A-53		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
CEMENT	7 Surface	250
PITLESS ADAPTOR	0	7

9. FORMATIONS

Kind	From (ft.)	To (ft.)
DIRT	0 Surface	6
LIMEROCK - CRELL	6	230
SANDROCK	230	337
SHALE	337	380

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on **8-14 1984**

11. MISCELLANEOUS DATA

Yield Test: **2** Hrs. at **10** GPM Well is terminated **10** inches above final grade below

Depth from surface to normal water level **300** Ft. Well disinfected upon completion Yes No

Depth of water level when pumping **310** Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to **MADISON** laboratory on **8-27 1984**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **Kenneth Lopian** Registered Well Driller Business Name and Complete Mailing Address **CARPAN WELL DRILLING BOSCABEL, WI. 53805**