

SEP 20 1976

State of Wisconsin
Department of Natural Resources
Box 450
Madison, Wisconsin 53701

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15
Rev. 10-75

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Seneca</u>	
2. LOCATION 1/4 Section <u>SE</u> Section <u>10</u> Township <u>10 N</u> Range <u>6 W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE		ADDRESS <u>Jack Haggerty</u> <u>R7D</u>	
OR - Grid or Street No. Street Name		POST OFFICE <u>Ferrisville, Wis. 54628</u>		AND - If available subdivision name, lot & block No.	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building, <u>15'</u>	Sanitary Bldg. Drain C.I. <u>22'</u> Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To C.I. Sewer Other Sewer
Street Sewer San. Storm		Foundation Drain Connected to Sewer Clearwater Dr.		Sewage Sump C.I. Other	Clearwater Sump
Other Sewers C.I. Other		Sewage Absorption Unit <u>85'</u> Seepage Pit Seepage Bed Seepage Trench		Septic Tank <u>60'</u>	Holding Tank
Privy	Pet Waste Pit	Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
5. Well is intended to supply water for: <u>Trailer home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>64</u>	<u>6</u>	<u>64</u>	<u>140</u>
					<u>Clay</u>
					<u>broken limestone</u>
					<u>soft shalestone</u>
					<u>hard shalestone</u>
					<u>sandstone</u>
7. CASING, LINER, CURBING AND SCREEN			From (ft.)		
Material, Weight, Specification & Method of Assembly			To (ft.)		
Dia. (in.)					
<u>6</u>	<u>new black steel P.E. 18.97</u>		<u>Surface</u>	<u>64</u>	
	<u>A-53</u>				
<u>Valley Steel</u>					
<u>Pitless adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind			From (ft.) To (ft.)		
<u>Clay</u>			<u>Surface</u>	<u>7</u>	
<u>Cement</u>			<u>7</u>	<u>64</u>	
			<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
			<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
			<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water
11. MISCELLANEOUS DATA			Well construction completed on <u>8-30-1976</u>		
Yield Test: <u>4</u> Hrs. at <u>8</u> GPM			Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
Depth from surface to normal water level <u>70</u> Ft.			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>78</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <u>Madison</u> laboratory on <u>9-14-1976</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Coplan</u>			Complete Mail Address <u>Boscobel, Wis. 53805</u>		
Registered Well Driller			<u>R3 Box 84</u>		