

1. COUNTY Crawford CHECK ONE Town Village City NAME Ferryville

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
S W 1/4 of Sec. 15 T 10 N R 6 W

3. OWNER AT TIME OF DRILLING
Mr. Mural Peick

4. OWNER'S COMPLETE MAIL ADDRESS
69 South Lexington, Janesville, Wis. 53545

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY C.I.	SEWER FILE	FLOOR DRAIN C.I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
		10'	20'	20'				

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		65'		90'					

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	41	6	41	100	Clay	Surface	10
						hard shale stone	10	65
						sandstone	65	100

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	41

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	10
Cement	10	41

11. MISCELLANEOUS DATA

Yield test: 6 Hrs. at 8 GPM Well is terminated 8 inches above below final grade

Depth from surface to normal water level 60 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 68 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison, Wis. laboratory on: 9-3- 1969

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS 53805 R3 Box 84 Boscobel, Wis.

Please do not write in space below

COLIFORM TEST RESULT 1025	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------	---------------	---------------	-----------	---------

RECEIVED
 SEP 08
 Dept. Nat.