

SEP 3 1974

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Freeman

2. LOCATION - 1/4 Section SE Section 15 Township 10N Range 6W 3. OWNER AT TIME OF DRILLING Mr. Allen B. Sampson

OR - Grid or street no. Street name ADDRESS RFD

AND - If available subdivision name, lot & block no. POST OFFICE Ferrisville, Wis., 54628

4. Distance in feet from well to nearest:

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
15'	25'	25'				

CLEAR WATER DRAIN C. I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		100'			125'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	196	6	196	440	Clay	Surface	20
						limestone	20	90
						soft sandstone	90	180
						limestone	180	240
						hard shalestone	240	325
						hard sandstone	325	440

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 18.99	Surface	196

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	20
Cement	20	196

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary

Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 8-15 1974

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 12 GPM

Well is terminated 10 inches  above  below final grade

Depth from surface to normal water level 360 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 367 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 8-28- 1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Roscobel, R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>1027</u> REV. 3-71	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
--	---------------	---------------	-----------	---------