

MAY 21 1973

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY <i>Crawford</i>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			NAME <i>Freeman</i>	
2. LOCATION - 1/4 Section <i>NW</i> Section <i>15</i> Township <i>10N</i> Range <i>6W</i>		3. OWNER AT TIME OF DRILLING <i>Mr. Joe Mc Namara</i>				
OR - Grid or street no.		Street name		ADDRESS <i>R7D</i>		
AND - If available subdivision name, lot & block no.			POST OFFICE <i>Ferryville, Wis, 54628</i>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	WASTE WATER DRAIN C.I.
		<i>20'</i>	<i>20'</i>			
CLEAR WATER DRAIN C.I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO
	<i>50'</i>			<i>65'</i>		
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)						

5. Well is intended to supply water for: *Trailer home*

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<i>6</i>	<i>Surface</i>	<i>160</i>				<i>loose sand</i>	<i>Surface</i>	<i>90</i>	
						<i>sandstone</i>	<i>90</i>	<i>160</i>	
7. CASING, LINER, CURBING, AND SCREEN									
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)					
<i>6</i>	<i>new black steel plain end 19.18</i>		<i>Surface</i>	<i>108</i>					

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<i>loose sand</i>	<i>Surface</i>	<i>90</i>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
			Well construction completed on <i>5-2-1973</i>		

11. MISCELLANEOUS DATA		Well is terminated <i>10</i> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade	
Yield test: <i>3</i> Hrs. at <i>12</i> GPM			
Depth from surface to normal water level <i>100</i> ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth to water level when pumping <i>102</i> ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		

Water sample sent to *Madison* laboratory on: *5-16-1973*

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Kenneth Coplan</i> Registered Well Driller	COMPLETE MAIL ADDRESS <i>Boacobel, R3 Box 84 Wis, 53805</i>
Please do not write in space below	

COLIFORM TEST RESULT <i>1028</i>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				