

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

FEB 16 1973

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

15123

1. COUNTY Crawford CHECK ONE Town Village City NAME Seneca

2. LOCATION - 1/4 Section SE Section 16 Township 10 N Range 6 W
OR - Grid or street no. Street name
3. OWNER AT TIME OF DRILLING Roger Heath
ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Ferryville Wis. 54628

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
<u>15'</u>	<u>25'</u>	<u>25'</u>				

CLEAR WATER DRAIN C. I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>70'</u>			<u>80'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>12</u>	<u>6</u>	<u>12</u>	<u>200</u>	<u>Clay</u>	<u>Surface</u>	<u>12</u>	
						<u>loose sand</u>	<u>12</u>	<u>150</u>	
						<u>sandstone</u>	<u>150</u>	<u>200</u>	

7. CASING, LINER, CURBING, AND SCREEN				
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>162</u>	

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)					
<u>Clay</u>	<u>Surface</u>	<u>12</u>	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Jetting with Air	<input type="checkbox"/> Jetting with Water
			<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air			

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Well is terminated 10 inches above final grade below

Depth from surface to normal water level 80 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 82 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 2-12-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>1029</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				