

MAR 1 E 1985

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Hanay

2. LOCATION SW 1/4 Section 14 Township 9N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Lyle George

OR - Grid or Street No. Street or Road Name ADDRESS R2

AND - If available subdivision name, lot & block No. POST OFFICE Haysville, Wis. ZIP CODE 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 50' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Clearwater Sump Holding Tank 120' Sewage Absorption Unit Seepage Pit 125' Seepage Bed Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	Surface	252'			
6"	252'	390'			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay & loose stone	Surface	197
soft sandstone	197	312
hard shalstone	312	390

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	new black steel plain end A-53 18.97 CA Conduwen or Valley Steel Pitless adaptor	Surface	252

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	252

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on Feb. 21 1985

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 10 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 300 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 310 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on March 11 1985

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Business Name and Complete Mailing Address Coplan Well Drilling R2 Box 4 Boscobel, Wis., 53805

103