

OCT 21 1977

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Seneca

2. LOCATION NW Section 26 Township 10 N Range 6 W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Robert B. Carter

OR - Grid or Street No. Street Name ADDRESS R 7 D

AND - If available subdivision name, lot & block No. POST OFFICE Ferrisville, Wis., 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Clearwater Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 75'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	61	6	61	85	Clay	Surface	30
						limestone	30	50
						sandstone	50	85

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53	Surface	61
	Valley Steel Pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	61

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-air w/drilling mud Rotary-w/drilling mud Rotary-hammer w/drilling mud & air Reverse Rotary Jetting with Air Water

Well construction completed on 9-28-77

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well is terminated 8 inches above final grade below

Depth from surface to normal water level 30 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 38 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 10-17 19 77

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cospian Registered Well Driller Complete Mail Address Boocobee, Wis. R3 Box 84 53805