

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

1973

27745

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Seneca
2. LOCATION - 1/4 Section SE Section 35 Township 10N Range 6W 3. OWNER AT TIME OF DRILLING Mrs. Ruth L. Hunter
OR - Grid or street no. Street name ADDRESS R7D
AND - If available subdivision name, lot & block no. POST OFFICE Lynsville, Wis. 54640
4. Distance in feet from well to nearest:
(Record answer in appropriate block)
BUILDING C.I. TILE 8' 20' FLOOR DRAIN C.I. TILE 20' FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT WASTE WATER DRAIN C.I. TILE
CLEAR WATER DRAIN C.I. TILE SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
70' 85'
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	145	6	145	180	Clay & sand sandstone	Surface	95	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	145

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
Clay Cement	Surface	95	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
	95	145	Well construction completed on <u>6-11-1973</u>		

11. MISCELLANEOUS DATA	
Yield test: <u>3</u> Hrs. at <u>8</u> GPM	Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level <u>150</u> ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping <u>152</u> ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison laboratory on: 7-30-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Box 84 R3 Boscobel, Wis. 53805
Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>1038</u>				<input checked="" type="checkbox"/>