

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

JAN 13 1981  
JAN 27 1981

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Haney

2. LOCATION SW 1/4 Section 15 Section Township 9N Range 4W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
Vernon & Clarence Ray  
ADDRESS R2

AND - If available subdivision name, lot & block No. POST OFFICE Says Mills, Wisc., 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 10' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Clearwater Sump Clearwater Sump Sewage Absorption Unit 175' Seepage Pit Seepage Bed Seepage Trench

Septic Tank 150' Holding Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>100</u>	<u>6</u>	<u>100</u>	<u>480</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel</u> <u>P.E., 18.97</u> <u>A-53</u> <u>Kent steel</u>	<u>0</u> Surface	<u>100</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay &amp; stone</u>	<u>0</u> Surface	<u>40</u>
<u>broken limestone</u>	<u>40</u>	<u>80</u>
<u>hard limestone</u>	<u>80</u>	<u>300</u>
<u>hard shale stone</u>	<u>300</u>	<u>400</u>
<u>hard sandstone</u>	<u>400</u>	<u>480</u>

RECEIVED  
JAN 20 1981

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>0</u> Surface	<u>3</u>
<u>Cement</u>	<u>3</u>	<u>100</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 1-6- 1981

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 12 inches  above final grade  below

Depth from surface to normal water level 360 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 375 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 1-8- 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address Boscobel, Wisc., R2 Box # 53805