

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

JUN 4 1973

21720 ✓

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

CRAWFORD

1. COUNTY Grant CHECK ONE Town Village City NAME Clayton

2. LOCATION - 1/4 Section NW Section 9 Township 11N Range 3W
OR - Grid or street no. NW Sec 19 Street name _____
3. OWNER AT TIME OF DRILLING Harold Sorenson
ADDRESS R7D

AND - If available subdivision name, lot & block no. _____ POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
20'	C. I. TILE 80'	C. I. TILE	SEWER CONNECTED INDEPENDENT	C. I. TILE 80'
CLEAR WATER DRAIN C. I. TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD
90'				95'

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface ⁰	52	6	52	120	Clay	Surface ⁰	15	
						soft sandstone	15	40	
						hard shalestone	40	90	
						sandstone	90	120	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface ⁰	52

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface ⁰	15
Cement	15	52

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 5-23- 19 73

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 8 GPM

Depth from surface to normal water level 60 ft.

Depth to water level when pumping 64 ft.

Well is terminated 11 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 5-29- 19 73

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel R3 Box 84 Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT <u>1044</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-------------------------------------	---------------	---------------	-----------	---------

REV. 3-71