

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION 1/2 Section NW Section 21 Township 11N Range 3W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
OR - Grid or Street No. Street Name ADDRESS Clyde Manschreck
RFD
AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, WI, 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 70' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump Clearwater Sump Sewage Absorption Unit 90' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

5. Well is intended to supply water for: Country home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	44	6	44	100	Clay & stone	Surface	25
						hard phalestone	25	70
						sandstone	70	100

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly Dia. (in.) From (ft.) To (ft.)
6 new black steel 0 44
P.E. 18.97 Surface
A-53
Keystone Pipe
Pitless adapter

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)
Clay Surface 7
Cement 7 44

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water
 Rotary-air w/drilling mud Rotary-hammer & air
 Rotary-w/drilling mud Reverse Rotary

Well construction completed on 11-23- 1979
Well is terminated 10 inches above below final grade
Well disinfected upon completion Yes No
Well sealed watertight upon completion Yes No

11. MISCELLANEOUS DATA
Yield Test: 2 Hrs. at 7 GPM
Depth from surface to normal water level 50 Ft.
Depth of water level when pumping 62 Ft. Stabilized Yes No
Water sample sent to Madison laboratory on 11-26- 1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address R2 Box 4 Boocobal, WI, 53805