

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

NOV 26 1971

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION - 1/4 Section SW Section 28 Township 11N Range 3W 3. OWNER AT TIME OF DRILLING Tom W. Davidson

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Soldiers Grove Wis. 54655

4. Distance in feet from well to nearest:

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
<u>30'</u>	<u>50'</u>	<u>50'</u>				

CLEAR WATER DRAIN C.I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	<u>65'</u>		<u>13'</u>	<u>70'</u>	<u>150'</u>	<u>200'</u>		

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>133</u>	<u>6</u>	<u>133</u>	<u>500</u>	<u>Clay</u>	<u>Surface</u>	<u>12</u>	
						<u>loose limestone</u>	<u>12</u>	<u>120</u>	
						<u>sandstone</u>	<u>120</u>	<u>270</u>	
						<u>limestone</u>	<u>270</u>	<u>475</u>	
						<u>sandstone</u>	<u>475</u>	<u>500</u>	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain ends 19.18</u>	<u>Surface</u>	<u>133</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>12</u>
<u>Cement</u>	<u>12</u>	<u>133</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 11-16-1971

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 0 ~~22~~ 380 GPM

Depth from surface to normal water level 380 ft.

Depth to water level when pumping 395 ft.

Well is terminated 12 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 11-22-1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coyman Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT <u>1050</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				