

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Clayton

2. LOCATION 1/4 Section SE Section 29 Township 11N Range 3W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Harold Dull

OR - Grid or Street No. Street Name ADDRESS R2 Box 255

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) 35'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer 85' Other Sewers 70' Foundation Drain Connected to: Sewage Sump 70' Clearwater Sump 70' Septic Tank 70' Holding Tank 70' Sewage Absorption Unit 85'

San.	Storm	C.I.	Other	Sewer	Sewage Sump	Clearwater Dr.	C.I.	Other	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
													Seepage Pit
													Seepage Bed
													Seepage Trench

Privy  Pet Waste Pit  Pit: Nonconforming Existing  Well Pump Tank  Subsurface Pumphouse  Nonconforming Existing  Barn Gutter  Animal Barn Pen  Animal Yard  Silo With Pit  Glass Lined Storage Facility  Silo w/o Pit  Earthen Silage Storage Trench Or Pit

Temporary Manure Stack  Watertight Liquid Manure Tank  Solid Manure Storage Structure  Subsurface Gasoline or Oil Tank  Waste Pond or Land Disposal Unit (Specify Type)  Other (Give Description)

5. Well is intended to supply water for: Farm home

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay & stone	Surface	112
soft sandstone	112	160
soft shalestone	160	180
hard shalestone	180	365
sandstone	365	380

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	198	6	198	380

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97	Surface	198
	A-53		
	Valley Steel		
	Pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	198

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Reverse Rotary  Jetting with  Air  Water

Well construction completed on 9-1-1978

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 296 Ft.

Depth of water level when pumping 304 Ft. Stabilized  Yes  No

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 9-20-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cospian Complete Mail Address Boscobel, Wis. R3 Box 84 53805

Registered Well Driller