

NOV 27 1979

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION 1/4 Section NE Section 30 Township 11N Range 3W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street Name ADDRESS John Iverson
RFD

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wis. 54653

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 100' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home 9. FORMATIONS

6. DRILLHOLE						Kind	From (ft.)	To (ft.)	
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)				
10	Surface	59	6	59	80	Clay & stone	Surface	0	20
						soft shale stone		20	40
						hard shale stone		40	80

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.97 A-53	Surface	59
	Keystone Pipe Bitless adapter		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	59

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water
 Rotary-air w/drilling mud Rotary-hammer & air
 Rotary-w/drilling mud Reverse Rotary

11. MISCELLANEOUS DATA
 Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above below final grade
 Depth from surface to normal water level 4.5 Ft. Well disinfected upon completion Yes No
 Depth of water level when pumping 56 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Well construction completed on 11-3- 19 79
 Water sample sent to Madison laboratory on 11-19- 19 79

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address R2 Box 4 Boscobel, Wis. 53805

1055