

MAY 20 1979

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Clayton</u>	
2. LOCATION OR - Grid or Street No. <u>NW</u> Section <u>31</u> Township <u>11 N</u> Range <u>3 W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Stan Peterson</u>			
AND - If available subdivision name, lot & block No.		ADDRESS <u>Soldiers Grove</u> POST OFFICE <u>WV. 54655</u>			
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>15'</u>		Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other	
Street Sewer		Foundation Drain Connected to:		Floor Drain Connected To:	
San. Storm C.I. Other		Sewer Sewage Sump Clearwater Dr. Clearwater Sump		C.I. Sewer Other Sewer C.I. Other	
Privy		Subsurface Pumproom		Sewage Absorption Unit <u>75'</u>	
Pet Waste Pit		Nonconforming Existing		Seepage Pit Seepage Bed Seepage Trench	
Pit: Nonconforming Existing		Barn Gutter		Holding Tank	
Well Pump Tank		Animal Barn Pen		Glass Lined Storage Facility	
Watertight Liquid Manure Tank		Animal Yard		Silo w/o Pit	
Solid Manure Storage Structure		Other (Give Description)		Earthen Silage Storage Trench Or Pit	
Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)			
Temporary Manure Stack					
5. Well is intended to supply water for: <u>Country home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind From (ft.) To (ft.)		
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)			<u>Clay's sand</u> Surface 0 50		
<u>10</u> Surface <u>0</u> <u>65</u> <u>6</u> <u>65</u> <u>120</u>			<u>hard sandstone</u> 50 120		
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly			From (ft.) To (ft.)		
Dia. (in.)					
<u>6</u> <u>new black steel</u> <u>0</u> <u>65</u>					
<u>P.E. 18' 97</u> <u>Surface</u>					
<u>A-53</u>					
<u>Kent Steel</u>					
<u>Pitless adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind From (ft.) To (ft.)			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with		
<u>loose sand</u> Surface <u>0</u> <u>7</u>			<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air		
<u>Cement</u> <u>7</u> <u>65</u>			<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
11. MISCELLANEOUS DATA			Well construction completed on <u>5-1-1979</u>		
Yield Test: <u>4</u> Hrs. at <u>5</u> GPM			Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth from surface to normal water level <u>80</u> Ft.			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>83</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <u>Madison</u> laboratory on <u>5-21-1979</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Coplan</u>		Complete Mail Address <u>Boacobal, WV.</u>			
Registered Well Driller		<u>R3 Box 84</u> <u>53805</u>			