

JUN 13 1977

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

NOTE:

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Clayton</u>													
2. LOCATION OR - Grid or Street No. <u>NE 19 11N 4W</u> AND - If available subdivision name, lot & block No.		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Paul Schockel</u>		ADDRESS <u>R7D Soldiers Grove</u> POST OFFICE <u>Wis. 54655</u>													
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>50'</u>		Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer					
		C.I. Other		C.I. Other		C.I. Sewer Other Sewer		C.I. Other		C.I. Other		C.I. Other					
Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank					
San. Storm		C.I. Other		Sewer Sewage Sump Clearwater Dr.		C.I. Other		Clearwater Sump		Septic Tank		Holding Tank					
Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard					
				Well Pump Tank		Nonconforming Existing				Silo With Pit		Glass Lined Storage Facility					
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)							
5. Well is intended to supply water for: <u>pig pen</u>						9. FORMATIONS											
6. DRILLHOLE																	
Dia. (in.)		From (ft.)		To (ft.)		Dia. (in.)		From (ft.)		To (ft.)		Kind		From (ft.)		To (ft.)	
<u>10</u>		<u>Surface</u>		<u>40</u>		<u>6</u>		<u>40</u>		<u>65</u>		<u>Clay</u>		<u>Surface</u>		<u>15</u>	
												<u>shalestone</u>		<u>15</u>		<u>65</u>	
7. CASING, LINER, CURBING AND SCREEN																	
Material, Weight, Specification																	
Dia. (in.)		& Method of Assembly		From (ft.)		To (ft.)											
<u>6</u>		<u>new black steel PE 18.97 A-53</u>		<u>Surface</u>		<u>40</u>											
<u>Valley Steel</u>																	
<u>Pitless adaptor</u>																	
8. GROUT OR OTHER SEALING MATERIAL						10. TYPE OF DRILLING MACHINE USED											
Kind		From (ft.)		To (ft.)		<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air		<input type="checkbox"/> Jetting with		<input type="checkbox"/> Air		<input type="checkbox"/> Water			
						<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air									
<u>Clay</u>		<u>Surface</u>		<u>7</u>		<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary									
<u>Cement</u>		<u>7</u>		<u>40</u>		Well construction completed on <u>May - 27 - 1977</u>											
11. MISCELLANEOUS DATA																	
Yield Test: <u>3</u> Hrs. at <u>6</u> GPM		Well is terminated <u>12</u> inches		<input checked="" type="checkbox"/> above final grade		<input type="checkbox"/> below											
Depth from surface to normal water level <u>35</u> Ft.		Well disinfected upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No													
Depth of water level when pumping <u>46</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No													
Water sample sent to <u>Madison</u> laboratory on <u>6-6-1977</u>																	

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller
 Complete Mail Address Boscobel, Wis. R3 Box 84 53805