

AUG 1 1977

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City				Name Utica			
2. LOCATION		1/4 Section SE	Section 30	Township 11	Range 4W	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Bill Culek			
OR - Grid or Street No.		Street Name				ADDRESS Rt. 1			
AND - If available subdivision name, lot & block No.						POST OFFICE Soldiers Grove, Wis. 54655			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 15	Sanitary Bldg. Drain C.I. Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer	Storm Bldg. Drain C.I. Other	Storm Bldg. Sewer C.I. Other		
Street Sewer San. Storm	Other Sewers C.I. Other	Foundation Drain Connected to: Sewer Clearwater Dr.	Sewage Sump C.I. Other	Clearwater Sump	Septic Tank 50	Holding Tank	Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench		
Privy	Pet Waste Pit	Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit		
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)				
5. Well is intended to supply water for: New Home					9. FORMATIONS				
6. DRILLHOLE					Kind	From (ft.)	To (ft.)		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)				
10	Surface	44	6	44	75	Clay & boulders	Surface		
						Sandstone	15		
						Shale	23		
7. CASING, LINER, CURBING AND SCREEN					/				
Dia. (in.)	Material, Weight, Specification & Method of Assembly		From (ft.)	To (ft.)					
6	Sced 40 18:97 P.E.		Surface	44					
	Pitless Adapter								
	ASTM-A-53								
	Valley Steel								
8. GROUT OR OTHER SEALING MATERIAL					10. TYPE OF DRILLING MACHINE USED				
Kind		From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input checked="" type="checkbox"/> Rotary-air w/drilling mud <input type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water					
Backfill		Surface	8	Well construction completed on 7/12/ 19 77					
Cement Grout		8	44						
11. MISCELLANEOUS DATA					Well is terminated 12 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade				
Yield Test: 5 Hrs. at 8 GPM		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
Depth from surface to normal water level 30 Ft.		Water sample sent to State laboratory on 7/12/ 19 77							
Depth of water level when pumping 35 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No									

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature *Albin Herbeck* Complete Mail Address **Box 136 Richland Center, Wis 53581**
Albin Herbeck #482 Registered Well Driller