

# Well Construction Report For WISCONSIN UNIQUE WELL NUMBER AK637


State of Wisconsin  
Department of Natural Resources  
Private Water Supply - WS/2  
Box 7921  
Madison, WI 53707

NOV 21 1989

Property Owner: Art. Hirtz Telephone Number: (608) 734-3681  
Mailing Address: Box 52 B  
City: Days Mills State: Wi. Zip Code: 54631  
County: Crawford County Well Location Permit No.: W Well Completion Date: 05 27 89

1. Location (Please type or print using a black pen.)  
 Town  City  Village Fire # (if available)  
of Haney  
Grid or Street Address or Road Name and Number (if available)  
Subdivision Name Lot # Block #

Well Constructor (Business Name) License #  
Corpian Well Drilling 75  
Address  
501 E. Oak  
City State Zip Code  
Boscobel Wi. 53805



Gov't Lot # of NW 1/4 of Section 30, T 9 N, R 4 W

3. Well Type  
 New  
 Replacement  Reconstruction/Rehabilitation  
of well constructed in 19 \_\_\_\_\_

Reason for new, reconstructed, replaced, or rehabilitated well?  
New Home  
 Drilled  Driven Point  Jetted  Other

4. Well serves 1 of homes and/or \_\_\_\_\_  
(ex: barn, restaurant, church, school, industry, etc.)  
High Capacity Well?  Yes  No  
High Capacity Property?  Yes  No

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings?  Yes  No  
Well Located in Floodplain?  Yes  No  
Distance In Feet From Well To Nearest:  
1. Landfill 45  
2. Building Overhang 42  
3. Septic or Holding Tank 80  
4. Sewage Absorption Unit \_\_\_\_\_  
5. Nonconforming Pit \_\_\_\_\_  
6. Buried Home Heating Oil Tank \_\_\_\_\_  
7. Buried Petroleum Tank \_\_\_\_\_  
8. Shoreline/Swimming Pool \_\_\_\_\_  
9. Downspout/Yard Hydrant \_\_\_\_\_  
10. Privy \_\_\_\_\_  
11. Foundation Drain to Clearwater \_\_\_\_\_  
12. Foundation Drain to Sewer \_\_\_\_\_  
13. Building Drain \_\_\_\_\_  
 Cast Iron or Plastic  Other \_\_\_\_\_  
14. Building Sewer  Gravity  Pressure  
 Cast Iron or Plastic  Other \_\_\_\_\_  
15. Collector Sewer \_\_\_\_\_  
16. Clearwater Sump \_\_\_\_\_  
17. Wastewater Sump \_\_\_\_\_  
18. Paved Animal Barn Pen \_\_\_\_\_  
19. Animal Yard or Shelter \_\_\_\_\_  
20. Silo - Type \_\_\_\_\_  
21. Barn Gutter \_\_\_\_\_  
22. Manure Pipe  Gravity  Pressure  
 Cast Iron or Plastic  Other \_\_\_\_\_  
23. Other Manure Storage \_\_\_\_\_  
Other NR 112 Waste Source \_\_\_\_\_  
24. \_\_\_\_\_

6. Drillhole Dimensions

Dia. (in.)	From (ft.)	To (ft.)
10	surface	168
6	168	405

Method of constructing upper enlarged drillhole. (If applicable more than one.)

1. Rotary - Mud Circulation  
 2. Rotary - Air  
 3. Rotary - Foam  
 4. Reverse Rotary  
 5. Cable-tool Bit \_\_\_\_\_ in. dia.  
 6. Temp. Outer Casing 10 in. dia.  
Removed?  Yes  No  
If no, explain \_\_\_\_\_  
 7. Other \_\_\_\_\_

9. Geology

Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
DIRT	surface	6
Loose rock & clay	6	16
Lump rock & crevice	16	243
Sand rock	243	288
Shale	288	405

7. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	New Black steel Plain End	surface	168
	ERP ASTM A-53-A		
	6x21 18.97		
Dia. (in.)	screen type and material	From	To

10. Static Water Level  
313 ft. below ground surface

11. Pump Test  
Pumping Level 341 ft. below surface  
Pumping at 7 GPM for 3 hours

12. Well Is:  
14 in.  Above Grade  Below  
Developed?  Yes  No  
Disinfected?  Yes  No  
Capped?  Yes  No

8. Grout or Other Sealing Material

Method	Kind of Sealing Material	From (ft.)	To (ft.)	Sacks Cement
<u>Tramex</u>	<u>Neat Cement</u>	surface	168	56

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?  
 Yes  No If no, explain None

14. Signature of Well Constructor: Michael D. Bender MB Date Signed: 6-19-89  
Signature of Drill Rig Operator: Michael D. Bender MB Date Signed: \_\_\_\_\_

Make additional comments on reverse side about geology, etc.