

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

SEP 12 1978

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Utica

2. LOCATION NE 30 11N 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Bessie Salmon

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) 15'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer 60' Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit

San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. C.I. Other Clearwater Sump Septic Tank Holding Tank Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphook Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>27</u>
<u>Clay & stone</u>	<u>27</u>	<u>28</u>
<u>hard shale stone</u>	<u>28</u>	<u>40</u>
<u>hard sandstone</u>	<u>40</u>	<u>60</u>

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>40</u>	<u>6</u>	<u>40</u>	<u>60</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel R.E. 18.97 A-53 Kent Steel Pitless adaptor</u>	<u>Surface</u>	<u>40</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>40</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 8-29-1978

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 5 GPM

Depth from surface to normal water level 30 Ft.

Depth of water level when pumping 42 Ft. Stabilized Yes No

Well is terminated 10 inches above final grade below

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 9-6-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Kopjan Registered Well Driller Complete Mail Address Boscobel, Wis. R3 Box 84 53805

1080