

JUN 13 1977

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Clayton

2. LOCATION SW 31 11N 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Gary Campbell
OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15' Sanitary Bldg. Drain C.I. 25' Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other
Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 60' Seepage Pit Seepage Bed Seepage Trench
Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit
Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>84</u>	<u>6</u>	<u>84</u>	<u>140</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>sands & Clay</u>	<u>Surface</u>	<u>40</u>
<u>shalestone</u>	<u>40</u>	<u>140</u>

7. CASING, LINER, CURBING AND SCREEN
Material, Weight, Specification

Dia. (in.)	& Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E 18-97</u>	<u>Surface</u>	<u>84</u>
	<u>A-53</u>		
	<u>Valley steel</u>		
	<u>Pitless adaptor</u>		

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay & sand</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>84</u>

Well construction completed on 5-16-1977

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 5 GPM

Well is terminated 10 inches above final grade below

Depth from surface to normal water level 80 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 86 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-6-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copron Registered Well Driller

Complete Mail Address R3 Box 84 Boscobel, Wis. 53805