

SEP 26 1977

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

NOTE:

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name <u>Clayton</u>								
2. LOCATION ¼ Section <u>SE</u> Section <u>33</u> Township <u>11N</u> Range <u>4W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Joe Skarda</u>			ADDRESS <u>R7D</u>								
OR - Grid or Street No.    Street Name		AND - If available subdivision name, lot & block No.			POST OFFICE <u>Soldiers Grove, Wis., 54655</u>								
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>50'</u>		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I.		Other		C.I.		Other		C.I.		Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank	
San.		Storm		C.I.		Other		Sewer		Clearwater Dr.		Sewage Sump	
												Sewage Absorption Unit <u>500'</u>	
												Seepage Pit	
												Seepage Bed	
												Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard	
				Well		Nonconforming Existing		<u>500'</u>				Silo With Pit	
				Pump								Glass Lined Storage Facility	
				Tank								Silo w/o Pit	
												Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)			
5. Well is intended to supply water for: <u>Farm home</u>						9. FORMATIONS							
						Kind		From (ft.)		To (ft.)			
6. DRILLHOLE						<u>Clay</u>		Surface <u>0</u>		<u>65</u>			
Dia. (in.)		From (ft.)		To (ft.)		Dia. (in.)		From (ft.)		To (ft.)			
<u>10</u>		<u>0</u>		<u>285</u>		<u>6</u>		<u>285</u>		<u>430</u>			
Surface													
7. CASING, LINER, CURBING AND SCREEN						<u>limestone</u>		<u>65</u>		<u>155</u>			
Material, Weight, Specification & Method of Assembly						<u>soft sandstone</u>		<u>155</u>		<u>170</u>			
Dia. (in.)		From (ft.)		To (ft.)		<u>limestone</u>		<u>170</u>		<u>205</u>			
<u>6</u>		<u>0</u>		<u>285</u>		<u>soft sandstone</u>		<u>205</u>		<u>260</u>			
<u>new black steel</u>		Surface				<u>hard shale stone</u>		<u>260</u>		<u>430</u>			
<u>P.E. 18.97</u>													
<u>A-53</u>													
<u>Valley Steel</u>													
<u>Pitless adaptor</u>													
8. GROUT OR OTHER SEALING MATERIAL						10. TYPE OF DRILLING MACHINE USED							
Kind		From (ft.)		To (ft.)		<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air		<input type="checkbox"/> Jetting with			
<u>Clay</u>		Surface <u>0</u>		<u>8</u>		<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air		<input type="checkbox"/> Air			
<u>Cement</u>		<u>8</u>		<u>285</u>		<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary		<input type="checkbox"/> Water			
11. MISCELLANEOUS DATA						Well construction completed on <u>9-3-1977</u>							
Yield Test: <u>3</u> Hrs. at <u>6</u> GPM		Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
Depth from surface to normal water level <u>332</u> Ft.													
Depth of water level when pumping <u>354</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No													
Water sample sent to <u>Madison</u> laboratory on <u>9-20-1977</u>													
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.													
Signature <u>Kenneth Copian</u> Registered Well Driller						Complete Mail Address <u>R3 Box 84 Boscobel, Wis. 53805</u>							