

NOV 20 1972

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

11076 ✓
STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY *Crawford* CHECK ONE Town Village City NAME *Clayton*

2. LOCATION - 1/4 Section *NW* Section *35* Township *11N* Range *4 W* 3. OWNER AT TIME OF DRILLING *Nerman Hansen*

OR - Grid or street no. Street name ADDRESS *R7D*

AND - If available subdivision name, lot & block no. POST OFFICE *Soldiers Grove Wis 54655*

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C.I.	C.I.	C.I.	SEWER CONNECTED	INDEPENDENT
TILE	TILE	TILE		
<i>10'</i>	<i>25'</i>	<i>25'</i>		

(Record answer in appropriate block)

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C.I.	TILE							
	<i>80'</i>		<i>90'</i>		<i>100'</i>			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: *Country farm home*

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<i>10</i>	<i>Surface</i>	<i>54</i>	<i>6</i>	<i>54</i>	<i>100</i>	<i>Clay</i>	<i>Surface</i>	<i>20</i>
						<i>soft shalestone</i>	<i>20</i>	<i>40</i>
						<i>hard shalestone</i>	<i>40</i>	<i>80</i>
						<i>sandstone</i>	<i>80</i>	<i>100</i>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<i>6</i>	<i>new black steel plain end 19.18</i>	<i>Surface</i>	<i>54</i>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<i>Clay</i>	<i>Surface</i>	<i>20</i>
<i>Cement</i>	<i>20</i>	<i>54</i>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on *10-31-1972*

11. MISCELLANEOUS DATA

Yield test: *3* Hrs. at *12* GPM

Depth from surface to normal water level *30* ft.

Depth to water level when pumping *42* ft.

Well is terminated *24* inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to *Madison* laboratory on: *11-15-1972*

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE *Benneth Cyprian* Registered Well Driller COMPLETE MAIL ADDRESS *Boakobel R3 Box 84 Hwy, 53805*

Please do not write in space below

COLIFORM TEST RESULT <i>10820</i>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				