

DEC 28 1976

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15
Rev. 10-75

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City <u>Utica</u>		Name	
2. LOCATION OR - Grid or Street No. <u>11N 5W</u> Street Name		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Mike Maman</u>		ADDRESS <u>Route 1</u>	
AND - If available subdivision name, lot & block No.		POST OFFICE <u>Soldiers Grove, WI</u>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>15'</u>		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		Storm Bldg. Drain		Storm Bldg. Sewer	
		Sewage Sump		Clearwater Sump	
		Septic Tank		Holding Tank	
		Sewage Absorption Unit <u>75'</u>			
		Seepage Pit			
		Seepage Bed			
		Seepage Trench			
5. Well is intended to supply water for: <u>Country Home</u>		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		<u>Clay</u>		<u>0 Surface 20</u>	
<u>10 0 Surface 150 6 150 375</u>		<u>Limestone</u>		<u>20 100</u>	
		<u>Soft Sandstone</u>		<u>100 140</u>	
		<u>Hard Sandstone</u>		<u>140 275</u>	
		<u>Fl Limestone</u>		<u>275 320</u>	
		<u>Hard Shalestone</u>		<u>320 375</u>	
7. CASING, LINER, CURBING AND SCREEN		10. TYPE OF DRILLING MACHINE USED			
Material, Weight, Specification & Method of Assembly		From (ft.) To (ft.)		<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water	
<u>6 P.E. New Blacksteel Valley Steel 18.97 A-53</u>		<u>0 Surface 150</u>		Well construction completed on <u>12-16</u> 19 <u>76</u>	
<u>Pitless Adapter</u>				Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below	
8. GROUT OR OTHER SEALING MATERIAL		Kind From (ft.) To (ft.)		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<u>Clay</u>		<u>0 Surface 8</u>		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<u>Cement</u>		<u>8 150</u>			
11. MISCELLANEOUS DATA		Yield Test: <u>3</u> Hrs. at <u>5</u> GPM			
Depth from surface to normal water level <u>290</u> Ft.		Water sample sent to <u>Madison</u> laboratory on <u>Dec. 20</u> 19 <u>76</u>			
Depth of water level when pumping <u>360</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.			

Signature
Kenneth Caprian
Registered Well Driller

Complete Mail Address
R 3, Box 84 - Boscoluel, WI 53805