

SEP 23 1986

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Bridgeport									
2. LOCATION 1/4 Section or Gov't. Lot NE 1/4 NE 1/4		Section 15	Township 6N	Range 6W	3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Blair Dillman								
OR - Grid or Street No. _____ Street or Road Name _____		ADDRESS R.R. 1											
AND - If available subdivision name, lot & block No. _____		POST OFFICE Prairie du Chien WI		ZIP CODE 53821									
4. Distance in feet from well to nearest: (Record answer in appropriate block)	Building	Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer			
	200'	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other		
Street Sewer	Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit			
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other			Seepage Pit	Manure Hopper or Retention or Pneumatic Tank		
				Clearwater Dr.	Clearwater Sump			150'		Seepage Bed 100'		Seepage Trench	
Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin		Other (Describe)			
								Concrete Floor Only					
								Concrete Floor and Partial Concrete Walls					
5. Well is intended to supply water for Private						9. FORMATIONS							
6. DRILLHOLE													
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)					
10	0	141				Dirt	Surface	4					
	Surface					Lime rock	4	69					
6	141	200				Crevice & clay	69	74					
7. CASING, LINER, CURBING AND SCREEN													
Material, Weight, Specification													
Dia. (in.)	Mfg. & Method of Assembly		From (ft.)	To (ft.)									
6	New Black Steel		Surface	0 141		Lime rock	74	89					
	Plain End					Soft Sand rock	89	130					
	KHC #18.97					Sand rock	130	181					
	.280W 6x21					Lime rock	181	200					
8. GROUT OR OTHER SEALING MATERIAL						10. TYPE OF DRILLING MACHINE USED							
Kind													
Bury Tank		From (ft.)	To (ft.)										
		Surface	0 7										
Cement		7	141										
11. MISCELLANEOUS DATA						Well construction completed on 9-8 19 86							
Yield Test: 2 Hrs. at 7 GPM						Well is terminated 10 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below							
Depth from surface to normal water level 123 Ft.						Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
Depth of water level when pumping 140 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No						Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
Water sample sent to MADISON laboratory on 9-23 19 86													
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.													
Signature Michael P. Blumberg						Business Name and Complete Mailing Address CORPIAN Well Drilling R.R. 2 Boscobel WI. 53805							