

JUN 13 1977

NOTE:  
White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
Form 3300-15  
Rev. 10-75

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Utica

2. LOCATION SE 26 11N 5W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
ADDRESS RFD  
POST OFFICE Soldiers Grove, Wis. 54655

AND -- If available subdivision name, lot & block No.

4. Distance in feet from well to nearest: (Record answer in appropriate block) 15'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer		
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other	
Street Sewer	Other Sewers	Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit <u>140'</u>			
San.	Storm	C.I.	Other	Sewer	Sewage Sump	Clearwater Sump	60'		Seepage Pit			
		Clearwater Dr.		Clearwater Sump					Seepage Bed			
Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well		Nonconforming Existing								
		Pump										
		Tank										
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)							

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	Kind	From (ft.)	To (ft.)
10	Surface	130	6	130	220	Clay	Surface	0	12
						sandstone		12	30
						limestone		30	220

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	<u>new black steel RE 18.97 A-53</u>	Surface	130
	<u>Valley Steel</u>		
	<u>Rittler's adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	Surface	7
<u>Cement</u>	7	130

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 5-25-1977

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Well is terminated 10 inches  above final grade  below

Depth from surface to normal water level 145 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 170 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 6-6-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cospian Registered Well Driller Complete Mail Address R 3 Box 84 Boonville, Wis. 53805