

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

FEB 27 1974

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY <i>Crawford</i>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			NAME <i>Freeman</i>	
2. LOCATION - 1/4 Section <i>NE</i> Section <i>30</i> Township <i>11N</i> Range <i>5W</i>		3. OWNER AT TIME OF DRILLING <i>Willard Fjelstad</i>				
OR - Grid or street no.		Street name			ADDRESS <i>R1</i>	
AND - If available subdivision name, lot & block no.		POST OFFICE <i>Ferrisville, Wis. 54628</i>				
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING <i>25'</i>	SANITARY SEWER C. I. <i>30'</i>	FLOOR DRAIN C. I. <i>30'</i>	FOUNDATION DRAIN SEWER CONNECTED	WASTE WATER DRAIN C. I. <input type="checkbox"/> TILE <input type="checkbox"/>
CLEAR WATER DRAIN C. I. <input type="checkbox"/> TILE <input type="checkbox"/>	SEPTIC TANK <i>70'</i>	PRIVY	SEEPAGE PIT	ABSORPTION FIELD <i>90'</i>	BARN	SILO
				ABANDONED WELL	SINK HOLE	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: *Country home*

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<i>10</i>	<i>Surface</i>	<i>65</i>	<i>6</i>	<i>65</i>	<i>320</i>	<i>Clay</i>	<i>Surface</i>	<i>15</i>	
						<i>broken limestone</i>	<i>15</i>	<i>48</i>	
						<i>hard limestone</i>	<i>48</i>	<i>180</i>	
						<i>sandstone</i>	<i>180</i>	<i>260</i>	
						<i>limestone</i>	<i>260</i>	<i>320</i>	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<i>6</i>	<i>new black steel plain end 19.18</i>	<i>Surface</i>	<i>65</i>

8. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
<i>Clay</i>	<i>Surface</i>	<i>15</i>
<i>Cement</i>	<i>15</i>	<i>65</i>

10. TYPE OF DRILLING MACHINE USED		
<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with Air <input type="checkbox"/> Water
Well construction completed on <i>2-11-1974</i>		

11. MISCELLANEOUS DATA	
Yield test: <i>3</i> Hrs. at <i>8</i> GPM	Depth from surface to normal water level <i>270</i> ft.
Depth to water level when pumping <i>274</i> ft.	

Well is terminated <i>10</i> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Water sample sent to <i>Madison</i> laboratory on: <i>2-21-1974</i>	

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Kenneth Copian</i> Registered Well Driller	COMPLETE MAIL ADDRESS <i>Boocobell, R3 Box 84 Wis. 53805</i>
------------------------------------------------------------	-----------------------------------------------------------------

COLIFORM TEST RESULT <i>1105</i> REV. 3-71	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS <i>L</i>
--------------------------------------------------	---------------	---------------	-----------	---------------------

Please do not write in space below