

1. COUNTY Crawford CHECK ONE Town Village City NAME Freemont

2. LOCATION - 1/4 Section SW Section 32 Township 11N Range 5W
OR - Grid or street no. Street name ADDRESS Jens Erneron
R1

AND - If available subdivision name, lot & block no. POST OFFICE Ferrysville, Wis. 54628

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING	SANITARY SEWER C.I.	SEWER TILE	FLOOR DRAIN C.I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
<u>25'</u>	<u>30'</u>						<u>30'</u>	

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		<u>70'</u>			<u>85'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Trailer Home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>82</u>	<u>6</u>	<u>82</u>	<u>120</u>	<u>Clay</u>	<u>Surface</u>	<u>12</u>
						<u>loose rock & Clay</u>	<u>12</u>	<u>25</u>
						<u>soft shalestone</u>	<u>25</u>	<u>70</u>
						<u>hard shalestone</u>	<u>70</u>	<u>120</u>

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97 A-53</u>	<u>Surface</u>	<u>82</u>
	<u>Valley Steel</u>		

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>Cement</u>	<u>Surface</u>	<u>82</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water

11. MISCELLANEOUS DATA		Well construction completed on	
Yield test:	<u>3</u> Hrs. at <u>8</u> GPM	<u>11-13-</u>	<u>1975</u>
Depth from surface to normal water level	<u>70</u> ft.	Well is terminated <u>12</u> inches	<input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below
Depth to water level when pumping	<u>78</u> ft.	Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison laboratory on: 12-15-1975

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coyjian Registered Well Driller COMPLETE MAIL ADDRESS Roscobel
R3 Box 84 Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT <u>1107</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-------------------------------------	---------------	---------------	-----------	---------