

OCT 21 1977

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Utica

2. LOCATION ¼ Section SE Section 34 Township 11 N Range 5 W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street Name ADDRESS Richard Wilhelm
RJD

AND - If available subdivision name, lot & block No. POST OFFICE Ferrisville, Wis., 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block)	Building	Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected to:		Storm Bldg. Drain		Storm Bldg. Sewer		
	<u>6'</u>	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other	
Street Sewer	Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit		
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.				Other	Seepage Pit	<u>60'</u>
Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)				

5. Well is intended to supply water for: Country home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>41</u>	<u>6</u>	<u>41</u>	<u>260</u>	<u>Clay</u>	<u>Surface</u>	<u>8</u>
						<u>limestone</u>	<u>8</u>	<u>200</u>
						<u>sandstone</u>	<u>200</u>	<u>260</u>

7. CASING, LINER, CURBING AND SCREEN			
Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel R.E. 18.97 A-53</u>	<u>Surface</u>	<u>41</u>
	<u>Pitless adaptor Valley Steel</u>		

8. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>41</u>

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Rotary-hammer w/drilling mud & air Jetting with
 Rotary-air w/drilling mud Rotary-hammer & air Air
 Rotary-w/drilling mud Reverse Rotary Water

11. MISCELLANEOUS DATA
 Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above final grade below
 Depth from surface to normal water level 180 Ft. Well disinfected upon completion Yes No
 Depth of water level when pumping 192 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 10-18-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cospian Registered Well Driller Complete Mail Address R3 Box 84 Boscobel, Wis., 53805