

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

FEB - 1 1973

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY **15120**

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Freeman

2. LOCATION - 1/4 Section SW 23 Section 11N Township 6W Range

OR - Grid or street no. Street name

3. OWNER AT TIME OF DRILLING Roy Hayden

ADDRESS R1

AND - If available subdivision name, lot & block no. POST OFFICE Ferrisville, Wis. 54628

4. Distance in feet from well to nearest:

BUILDING C.I.	SANITARY C.I.	SEWER TILE	FLOOR DRAIN C.I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
<u>8'</u>	<u>40'</u>		<u>40'</u>					

(Record answer in appropriate block)

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>70'</u>		<u>80'</u>		<u>150'</u>	<u>150'</u>	<u>100'</u>	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>100</u>	<u>6</u>	<u>100</u>	<u>380</u>	<u>Clay</u>	<u>Surface</u>	<u>70</u>	
						<u>loose limestone</u>	<u>70</u>	<u>80</u>	
						<u>hard limestone</u>	<u>80</u>	<u>260</u>	
						<u>sandstone</u>	<u>260</u>	<u>330</u>	
						<u>shalestone</u>	<u>330</u>	<u>380</u>	

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)		<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	
<u>Clay</u>	<u>Surface</u>	<u>70</u>		<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water	
<u>Cement</u>	<u>70</u>	<u>100</u>		Well construction completed on <u>1-3-</u> <u>1973</u>			

11. MISCELLANEOUS DATA			
Yield test:	<u>3</u> Hrs. at	<u>8</u> GPM	Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level	<u>280</u> ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	<u>300</u> ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison laboratory on: 1-29- 1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Boacobel, R3 Box 84, Wis. 53805

COLIFORM TEST RESULT 1113 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS

REV. 3-71