

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

MAY 29 1979

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Freeman</u>	
2. LOCATION 1/4 Section <u>SW</u> Section <u>28</u> Township <u>11N</u> Range <u>6W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Mary E. Belg</u>			
OR - Grid or Street No. Street Name		ADDRESS <u>RFD</u>			
AND - If available subdivision name, lot & block No.		POST OFFICE <u>Ferrysville, Wis., 54628</u>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>35'</u>		Sanitary Bldg. Drain	
		Sanitary Bldg. Sewer		Floor Drain Connected To:	
		Storm Bldg. Drain		Storm Bldg. Sewer	
		Street Sewer		Sewage Absorption Unit <u>95'</u>	
		Other Sewers		Sewage Sump	
		Foundation Drain Connected to:		Clearwater Sump	
		Sewer		Septic Tank <u>80'</u>	
		Clearwater Dr.		Holding Tank	
Privy		Pet Waste Pit		Sewage Absorption Unit	
Pit: Nonconforming Existing		Subsurface Pumproom		Seepage Pit	
Well		Barn Gutter		Seepage Bed	
Pump		Animal Barn Pen		Seepage Trench	
Tank		Animal Yard			
Temporary Manure Stack		Waste Pond or Land Disposal Unit (Specify Type)			
Watertight Liquid Manure Tank		Other (Give Description)			
Solid Manure Storage Structure					
Subsurface Gasoline or Oil Tank					
5. Well is intended to supply water for: <u>Country home</u>		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		<u>Clay & stone</u>		Surface 0 35	
<u>10</u> Surface 0 49 <u>6</u> 49 <u>120</u>		<u>hard shalestone</u>		35 100	
		<u>sandstone</u>		100 120	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly		From (ft.) To (ft.)			
<u>6 new black steel P.E. 18.97</u>		Surface 0 49			
<u>A-53</u>					
<u>Kent Steel</u>					
<u>Pitless adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED			
Kind From (ft.) To (ft.)		<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drifting mud & air	
<u>Clay</u> Surface 0 7		<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air	
<u>Cement</u> 7 49		<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary	
				<input type="checkbox"/> Jetting with	
				<input type="checkbox"/> Air	
				<input type="checkbox"/> Water	
11. MISCELLANEOUS DATA		Well construction completed on <u>4-8-1979</u>			
Yield Test: <u>2</u> Hrs. at <u>5</u> GPM		Well is terminated <u>10</u> inches		<input checked="" type="checkbox"/> above final grade	
Depth from surface to normal water level <u>80</u> Ft.		Well disinfected upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth of water level when pumping <u>86</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Water sample sent to <u>Madison</u> laboratory on <u>5-21-1979</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Copian</u>		Complete Mail Address <u>Boscobel, Wis.</u> <u>R3 Box 84</u> <u>53805</u>			
Registered Well Driller					