

OCT 10 1979

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

JAN 30 1980

DEC 27 1979

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION ¼ Section 22 Township 10N Range 7W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE City of De Soto

OR - Grid or Street No. Street Name 11N ADDRESS De Soto, Wis. 54624

AND If available subdivision name, lot & block No. Village of De Soto Lot 1-2-3-4 POST OFFICE De Soto, Wis. 54624

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>20'</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
San. Storm	C.I. Other	Sewer	Sewage Sump Clearwater Sump	C.I. Other			Seepage Pit Seepage Bed Seepage Trench

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well Pump Tank	Nonconforming Existing							

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)

5. Well is intended to supply water for: apt. homes

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>80</u>	<u>6</u>	<u>80</u>	<u>180</u>	<u>Clay</u>	<u>Surface</u>	<u>80</u>
						<u>sand & gravel</u>	<u>80</u>	<u>120</u>
						<u>sandstone</u>	<u>120</u>	<u>180</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53 Kent Steel Pitless adapter</u>	<u>Surface</u>	<u>142</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>10</u>
<u>Cement</u>	<u>10</u>	<u>142</u>

Well construction completed on 9-17-1979

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 20 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 100 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 114 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 10-3-1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copson Complete Mail Address R2 Box 4 Boscobel, Wis. 53805

Registered Well Driller

1124