

APR 30 1974

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Freeman

2. LOCATION - 1/4 Section S 2 NE, 5 SW Section 24 Township 10 N Range 7 W 3. OWNER AT TIME OF DRILLING Helenda J. Freeman

OR - Grid or street no. Street name 11N ADDRESS R1

AND - If available subdivision name, lot & block no. POST OFFICE Ferrisville, Wis. 54628

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	C. I.	C. I.	SEWER CONNECTED	C. I.
TILE	TILE	TILE	INDEPENDENT	TILE
<u>10'</u>	<u>20'</u>			

(Record answer in appropriate block)

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	<u>250'</u>			<u>260'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>60</u>	<u>6</u>	<u>60</u>	<u>200</u>	<u>Clay</u>	<u>Surface</u>	<u>25</u>
						<u>Clay & stone</u>	<u>25</u>	<u>45</u>
						<u>hard shale stone</u>	<u>45</u>	<u>180</u>
						<u>sandstone</u>	<u>180</u>	<u>200</u>

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)		<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	
<u>Clay</u>	<u>Surface</u>	<u>25</u>		<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with	
<u>Cement</u>	<u>25</u>	<u>60</u>				<input type="checkbox"/> Air <input type="checkbox"/> Water	

Well construction completed on 4-16 1974

11. MISCELLANEOUS DATA				Well is terminated			
Yield test:	<u>3</u> Hrs. at	<u>8</u> GPM		<u>10</u> inches	<input checked="" type="checkbox"/> above	<input type="checkbox"/> below	final grade
Depth from surface to normal water level	<u>145</u> ft.			Well disinfected upon completion	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Depth to water level when pumping	<u>152</u> ft.			Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	

Water sample sent to Madison laboratory on: 4-25-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coprian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>1127</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-------------------------------------	---------------	---------------	-----------	---------

REV. 3-71