

NOV 18 1985 SEP 4 1985

1. COUNTY **CRAWFORD** CHECK (✓) ONE: Town Village City Name **Seneca**

2. LOCATION **SW 1/4 NW 1/4** Section **1** Township **9N** Range **5W** 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE **FRANK STARR**

OR - Grid or Street No. Street or Road Name ADDRESS **Rt. 1 Box 101**

AND - If available subdivision name, lot & block No. POST OFFICE **GAUS MILLS** WI ZIP CODE **54631**

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
81	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San. Storm	C.I. Other	Sewer Sewer	C.I. Other	Clearwater Sump	100'		Seepage Pit Seepage Bed 250' Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: **Private**

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	0 Surface	42			
6"	42	80			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
LOOSE ROCK + DIRT	0 Surface	7
SOFT SHALE	7	38
HARD SHALE	38	80

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	Plain End New Black Steel	0 Surface	42
	CA Conduven A53		
	.280W x #18 97		

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on **8-23** 19 **85**

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	70 Surface	42
Pitless Adaptor	0	7

11. MISCELLANEOUS DATA

Yield Test: **2** Hrs. at **7** GPM Well is terminated **10** inches above final grade below

Depth from surface to normal water level **29** Ft. Well disinfected upon completion Yes No

Depth of water level when pumping **44** Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to **MADISON, WI** laboratory on **8-27** 19 **85**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **Michael O. Bamboer** Registered Well Driller Business Name and Complete Mailing Address **CORPIAN WELL DRILLING INC. BOSCOBEL, WI. 53805**