

WELL CONSTRUCTOR'S REPORT

Well-6

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Freeman

2. LOCATION (Number and Street of 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
SE 1/4 of Sec. 35 T 10 N 11 N? R 7 W

3. OWNER AT TIME OF DRILLING Don Nerfert

4. OWNER'S COMPLETE MAIL ADDRESS
R2 De Soto, Wis., 54624

5. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C.I.	TILE	C.I.	SEWER CONNECTED	INDEPENDENT
3'	30'	30'		
C.I.	TILE	C.I.	TILE	

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C.I.	TILE							
	60'		70'					

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Trailer home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	98	6	98	300	Clay	Surface	15
						clay & loose rock	15	60
						hard sandstone	60	90
						hard shalestone	90	250
						sandstone	250	300

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19-18	Surface	98

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	15
Cement	15	98

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 10 GPM

Well is terminated 12 inches above below final grade

Depth from surface to normal water level 260 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 265 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9-20-1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
1132				