

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

AUG 16 1974

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Freeman

2. LOCATION - 1/4 Section 35 Section 11N Township 7W Range 7W
OR - Grid or street no. Street name ADDRESS Mickel Dagnan Resoto

AND - If available subdivision name, lot & block no. Lot - 6-7 New Resoto along Hwy 35 POST OFFICE Resoto wisca

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C. I.	TILE
	<u>10'</u>						

CLEAR WATER DRAIN C. I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		<u>70</u>		<u>100</u>					

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for:

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10"</u>	<u>Surface</u>	<u>63'</u>	<u>6"</u>	<u>63</u>	<u>145</u>	<u>Shale</u>	<u>Surface</u>	<u>63</u>
						<u>Sandstone</u>	<u>63</u>	<u>145</u>

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6"</u>	<u>Black PVC new STD. 1940</u>	<u>Surface</u>	<u>63</u>

8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED	
Kind	From (ft.)	To (ft.)	
<u>Cement</u>	<u>Surface</u>	<u>63</u>	<input type="checkbox"/> Cable Tool <input checked="" type="checkbox"/> Direct Rotary <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Rotary - air w/drilling mud <input type="checkbox"/> Rotary - hammer with drilling mud & air <input type="checkbox"/> Jetting with Air <input type="checkbox"/> Water

11. MISCELLANEOUS DATA			
Yield test:	<u>15</u>	Hrs. at	<u>10</u> GPM
Depth from surface to normal water level	<u>100</u>	ft.	
Depth to water level when pumping	<u>126</u>	ft.	

Well construction completed on 8/3 19 74
Well is terminated 14 inches above below final grade
Well disinfected upon completion Yes No
Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 8/15 19 74

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Edwin W. [Signature] Registered Well Driller COMPLETE MAIL ADDRESS New Albin Iowa
Please do not write in space below

COLIFORM TEST RESULT <u>1135</u> REV. 3-71	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
--	---------------	---------------	-----------	---------