

1. COUNTY **CRAWFORD** CHECK (✓) ONE: Town Village City Name **SENECA**

2. LOCATION **SE** **11 9N SW** 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE **TOM BAKER**

OR - Grid or Street No. Street or Road Name ADDRESS **9AYS MILLS WI 54631**

AND - If available subdivision name, lot & block No. POST OFFICE ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block) **45'**

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit		Manure Hopper or Retention or Pneumatic Tank	
San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank					
				Clearwater Dr.	Clearwater Sump						Seepage Pit				Seepage Bed 120'		
											Seepage Trench						

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well	Nonconforming Existing								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only	
					Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: **COUNTRY HOME**

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	Surface	336			
6"	336	385			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	NEW BLACK STEEL PLAIN END	Surface	336
	A-53 18.99		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
CLAY	Surface	14
LIMEROCK - CRU.	14	57
SOFT SANDSTONE	57	287
SOFT SHALESTONE	287	300
HARD LIMESTONE	300	385

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
CEMENT	Surface	336
BURRY TANK	0	7

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on **9-28 1983**

11. MISCELLANEOUS DATA

Yield Test: **3** Hrs. at **6** GPM

Well is terminated **10** inches above below final grade

Depth from surface to normal water level **250** Ft. Well disinfected upon completion Yes No

Depth of water level when pumping **260** Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to **MADISON** laboratory on **10-3 1983**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature **117 Kenneth Copian** Registered Well Driller

Business Name and Complete Mailing Address **COPIAN WELL DRILLING BOSELABEL, WI. 53805**