

SEP 4 1981

| | | | | | | | | | |
|--|--|--|--|--|--|--|--|---|--|
| 1. COUNTY | | Crawford | | CHECK (✓) ONE: | | Name | | Gays Mills | |
| | | | | <input checked="" type="checkbox"/> Town | | <input type="checkbox"/> Village | | <input type="checkbox"/> City | |
| 2. LOCATION | | 1/4 Section or Gov't. Lot | | Section | | Township | | Range | |
| NW of NW | | 13 | | 9N | | 5W | | 3. NAME | |
| OR - Grid or Street No. | | Street or Road Name | | ADDRESS | | POST OFFICE | | ZIP CODE | |
| | | | | Harvey Sheets | | Gays Mills Wi | | 54631 | |
| 4. Distance in feet from well to nearest: | | Building | | Sanitary Bldg. Drain | | Sanitary Bldg. Sewer | | Floor Drain Connected To: | |
| (Record answer in appropriate block) | | 20' | | C.I. Other | | C.I. Other | | C.I. Sewer Other Sewer | |
| Street Sewer | | Other Sewers | | Foundation Drain Connected to: | | Sewage Sump | | Clearwater Sump | |
| San. Storm | | C.I. Other | | Sewer Sewage Sump | | C.I. Other | | Septic Tank Holding Tank | |
| | | | | Clearwater Dr. Clearwater Sump | | | | Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench | |
| Privy | | Pet Waste Pit | | Pit: Nonconforming Existing | | Subsurface Pumproom | | Barn Gutter | |
| | | | | Well Pump Tank | | Nonconforming Existing | | Animal Barn Pen Animal Yard Silo With Pit | |
| Temporary Manure Stack or Platform | | Watertight Liquid Manure Tank or Basin | | Manure Pressure Pipe | | Subsurface Gasoline or Oil Tank | | Waste Pond or Land Disposal Unit (Specify Type) | |
| | | | | | | | | Manure Storage Basin: Concrete Floor Only Concrete Floor and Partial Concrete Walls | |
| 5. Well is intended to supply water for: | | country home | | 9. FORMATIONS | | Kind | | From (ft.) To (ft.) | |
| 6. DRILLHOLE | | Dia. (in.) | | From (ft.) | | To (ft.) | | Surface | |
| 10 | | Surface | | 210 | | 360 | | Clay 0 12 | |
| | | | | | | | | sand rock 12 80 | |
| | | | | | | | | lime rock 80 310 | |
| | | | | | | | | sand rock 310 360 | |
| 7. CASING, LINER, CURBING AND SCREEN | | Material, Weight, Specification | | From (ft.) | | To (ft.) | | | |
| Dia. (in.) | | Mfg. & Method of Assembly | | Surface | | 210 | | | |
| 6 | | new black steel PE 18.97 | | Surface | | 210 | | | |
| | | A-53 Valley Steel pitless adapter | | | | | | | |
| 8. GROUT OR OTHER SEALING MATERIAL | | Kind | | From (ft.) | | To (ft.) | | 10. TYPE OF DRILLING MACHINE USED | |
| | | clay | | Surface | | 8 | | <input type="checkbox"/> Cable Tool | |
| | | cement | | 8 | | 210 | | <input type="checkbox"/> Rotary-hammer w/drilling mud & air | |
| | | | | | | | | <input checked="" type="checkbox"/> Rotary-hammer & air | |
| | | | | | | | | <input type="checkbox"/> Jetting with | |
| | | | | | | | | <input type="checkbox"/> Air | |
| | | | | | | | | <input type="checkbox"/> Water | |
| 11. MISCELLANEOUS DATA | | Yield Test: 3 | | Hrs. at 7 | | GPM | | Well construction completed on 8-15 1981 | |
| | | Depth from surface to normal water level 290 | | Ft. | | Well is terminated 12 inches | | <input checked="" type="checkbox"/> above final grade | |
| | | Depth of water level when pumping 295 | | Ft. | | Well disinfected upon completion | | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| | | Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | | | Well sealed watertight upon completion | | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| | | Water sample sent to Madison | | laboratory on 9-1 | | 1981 | | | |
| Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side. | | Signature | | Business Name and Complete Mailing Address | | RT4 Box 75 | | Done Well Drilling, Rosabel Wis 54665 | |
| 118 | | Donald C. Kirchbaum | | Registered Well Driller | | | | | |

RECEIVED
SEP 10 1981
DNR - Well