

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

AUG 5 1985

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Seneca

2. LOCATION NE of SE Section 1 Township 9N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE W Wayne Chambers

OR - Grid or Street No. Street or Road Name ADDRESS Box 207

AND - If available subdivision name, lot & block No. POST OFFICE Eastman Wi ZIP CODE 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) 30'

| Building | | Sanitary Bldg. Drain | | Sanitary Bldg. Sewer | | Floor Drain Connected To: | | Storm Bldg. Drain | | Storm Bldg. Sewer | |
|----------|-------|----------------------|-------|----------------------|-------|---------------------------|-------------|-------------------|-------|-------------------|-------|
| C.I. | Other | C.I. | Other | C.I. | Other | C.I. Sewer | Other Sewer | C.I. | Other | C.I. | Other |

| Street Sewer | | Other Sewers | | Foundation Drain Connected to: | | Sewage Sump | | Clearwater Sump | Septic Tank | Holding Tank | Sewage Absorption Unit | | Manure Hopper or Retention or Pnuematic Tank |
|--------------|-------|--------------|-------|--------------------------------|----------------|-------------|-------|-----------------|-------------|--------------|------------------------|-------------|--|
| San. | Storm | C.I. | Other | Sewer | Clearwater Dr. | C.I. | Other | | | | Seepage Pit | Seepage Bed | |

| Privy | Pet Waste Pit | Pit: Nonconforming Existing | | Subsurface Pumproom | | Barn Gutter | Animal Barn Pen | Animal Yard | Silo With Pit | Glass Lined Storage Facility | Silo w/o Pit | Earthen Silage Storage Trench Or Pit | Earthen Manure Basin |
|-------|---------------|-----------------------------|------|------------------------|--|-------------|-----------------|-------------|---------------|------------------------------|--------------|--------------------------------------|----------------------|
| | | Well | Pump | Nonconforming Existing | | | | | | | | | |

| Temporary Manure Stack or Platform | Watertight Liquid Manure Tank or Basin | Manure Pressure Pipe | Subsurface Gasoline or Oil Tank | Waste Pond or Land Disposal Unit (Specify Type) | Manure Storage Basin | | Other (Describe) |
|------------------------------------|--|----------------------|---------------------------------|---|----------------------|---|------------------|
| | | | | | Concrete Floor Only | Concrete Floor and Partial Concrete Walls | |

5. Well is intended to supply water for: country home

6. DRILLHOLE

| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) |
|------------|----------------|-----------|------------|------------|-----------|
| <u>10</u> | <u>Surface</u> | <u>64</u> | <u>6</u> | <u>64</u> | <u>80</u> |

9. FORMATIONS

| Kind | From (ft.) | To (ft.) |
|--------------------|----------------|------------|
| <u>clay</u> | <u>Surface</u> | <u>30</u> |
| <u>loose rocks</u> | <u>30</u> | <u>45-</u> |
| <u>shale</u> | <u>45-</u> | <u>80</u> |

7. CASING, LINER, CURBING AND SCREEN

| Dia. (in.) | Material, Weight, Specification | From (ft.) | To (ft.) |
|------------|--|----------------|-----------|
| <u>6</u> | <u>new black steel PE 18.97 PSI 1200 A-150 DSP PIPES adapter</u> | <u>Surface</u> | <u>64</u> |

10. TYPE OF DRILLING MACHINE USED

| | | |
|--|---|---------------------------------------|
| <input type="checkbox"/> Cable Tool | <input type="checkbox"/> Rotary-hammer w/drilling mud & air | <input type="checkbox"/> Jetting with |
| <input type="checkbox"/> Rotary-air w/drilling mud | <input checked="" type="checkbox"/> Rotary-hammer & air | <input type="checkbox"/> Air |
| <input type="checkbox"/> Rotary-w/drilling mud | <input type="checkbox"/> Reverse Rotary | <input type="checkbox"/> Water |

8. GROUT OR OTHER SEALING MATERIAL

| Kind | From (ft.) | To (ft.) |
|---------------|----------------|-----------|
| <u>clay</u> | <u>Surface</u> | <u>8</u> |
| <u>cement</u> | <u>8</u> | <u>64</u> |

Well construction completed on 4-10 1985

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM

Well is terminated 12 inches above below final grade

Depth from surface to normal water level 40 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 42 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-19 1985

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kuchman Registered Well Driller Business Name and Complete Mailing Address Rt 4/Box 75 Dons Well Drilling Basebel Wis 53805

124