

MAY 21 1980

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Seneca

2. LOCATION Section N2, 23 Township 9N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE William Peterson

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Lynxville, Wis. 54640

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Absorption Unit 85' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Sild With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	103	6	103	140	Clay & stone	Surface	0	25
						soft shalestone		25	80
						hard sandstone		80	140

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	103
<u>new black steel P.E. 18.97 A-53 Kent Steel Pitless adapter</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	Surface	8
<u>Cement</u>	8	103

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 48 GPM Well is terminated 10 inches  above  below final grade

Depth from surface to normal water level 25 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 54 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 5-15- 19 80

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Popian Registered Well Driller Complete Mail Address Booscobel, Wis. R2-Box 4 53805