

SEP 1 1981
JUL 21 1981

1. COUNTY Crawford CHECK (✓) ONE:
 Town Village City Lynxville Name
 2. LOCATION NW Section 23 Township 9N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street or Road Name ADDRESS 3137 North 91st
 AND - If available subdivision name, lot & block No. POST OFFICE Milwaukee, WI ZIP CODE

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>7'</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other
		<u>40'</u>			

Street Sewer: San. Storm Other Sewers: C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump

50' Septic Tank Holding Tank Sewage Absorption: Seepage Pit Seepage Bed Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy: Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin: Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>62</u>	<u>6</u>	<u>62</u>	<u>67</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>loose rock</u>	<u>Surface</u>	<u>47</u>
<u>soft shale</u>	<u>47</u>	<u>52</u>
<u>hard shale</u>	<u>52</u>	<u>67</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>P.E.</u>	<u>18.97</u>	<u>Surface</u>	<u>62</u>
	<u>A53</u>	<u>Lynxville Pipe</u>		
	<u>+ Sube</u>			
	<u>fitless adapter</u>			

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drifting mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 4/20 1981

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>62</u>

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 15 inches above below final grade

Depth from surface to normal water level 10 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 15 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 9-13 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature: [Signature] Registered Well Driller Business Name and Complete Mailing Address: Kenneth Corplan & Sons, Inc
Rt. 2 Box 4 Boscobel, WI 53805