

State of Wisconsin  
 Department of Natural Resources  
 Private Water Supply  
 Box 7921  
 Madison, Wisconsin 53707

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
 Form 3300-15 Rev. 5-85

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Seneca

2. LOCATION NE of NE 1/4 Section or Gov't. Lot Section 23 Township 9N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Mary Linder

OR - Grid or Street No. Street or Road Name ADDRESS RR Box 164

AND - If available subdivision name, lot & block No. POST OFFICE Eastman Wj ZIP CODE 54626

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Manure Hopper or Retention or Pneumatic Tank

San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. Clearwater Sump C.I. Other 50 55

Privy Pet Waste Pit Pit: Nonconforming Existing Subsurface Pumproom Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: trailer home 9. FORMATIONS

Kind	From (ft.)	To (ft.)
clay	Surface	12
lime rock	12	50
shale	50	100

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	90	6	90	100

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	new black steel PE 18.97	Surface	90
	PSI-1200		
	A-120		
	USP pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	90

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on 11-12 1986

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well is terminated 12 inches  above final grade  below

Depth from surface to normal water level 60 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 62 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 1-20 1987

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature

Donald C. Kuehn Registered Well Driller

Business Name and Complete Mailing Address 16189 Dutch Hill Rd

Don's Well Drilling Rosabel Wj 53805