

NOTE:
 White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

SEP 1 1981
 JUL 2 1981
 WOD

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Seneca

2. LOCATION DE Section 24 Township 9N Range 6W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Jan Van Dresser

OR - Grid or Street No. Street or Road Name ADDRESS RFD 1

AND - If available subdivision name, lot & block No. POST OFFICE Walworth ZIP CODE WI

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 2.0' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storage C.I. Other Other Sewers Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C. Sewage Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench Manure Hopper or Retention or Phosphoric Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: mobile home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	60	6	60	100	loose stone	Surface	50
						hard shale stone	50	78
						hard limestone	78	100

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	Mfg. & Method of Assembly	From (ft.)	To (ft.)
6	P.E. 18.97 lbs/ft	Surface	0	60
	A53 Luxington			
	Pipe & Tube			

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
Cement	8	60

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-air w/drilling mud Rotary-w/drilling mud Rotary-hammer w/drilling mud & air Reverse Rotary Jetting with Air Water

Well construction completed on 6-19 1981

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 7 GPM Well is terminated 18 inches above below final grade

Depth from surface to normal water level 50 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 55 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 7-13 1981

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature R. J. Coplan Registered Well Driller Business Name and Complete Mailing Address Kenneth Coplan & Sons, Inc
132 P.O. 2 Box 4 - Basco, WI 53805